

CERTIFICATE OF ANALYSIS

						te: <u>JUN.20,2018</u> t No: <u>AH118-2018</u>
PUROLITE				ION EXCHANGE RESIN MB400		
BATCH NO				6022H/07/18		
Quantity			160 BAGS			
Total capacity eq/I			1.83/1.20			
cation H/anion OH						
Moisture Content %			65.4%			
Whole bead %			99. 0			
Partic	<0.300 mm	%		NIL		
le	>1.200 mm	%		NIL		
size						
Uniformity Coefficient			1.7			
Specific Gravity			1.27			
Shipping weight g/1			720			
Temperature Limit			120°C			



REF NO: HY316022

